

Environment Protection Licence

Licence - 10020



Environment,
Climate Change
& Water

Licence Details

Number:	10020
Anniversary Date:	30-June

Licensee

SYDNEY OLYMPIC PARK AUTHORITY
 LOCKED BAG 3, SYDNEY OLYMPIC PARK
 HOMEBUSH BAY NSW 2127

Licence Type

Premises

Premises

SYDNEY OLYMPIC PARK
 Marjorie Jackson Parkway, Edwin Flack Avenue
 HOMEBUSH BAY NSW 2127

Non Scheduled Activity

Water Reclamation and Recycling Scheme

Fee Based Activity**Scale**

Miscellaneous Licensed Discharge to Waters (at any time)	0 - 20 ML discharged
Sewage treatment - processing by small plants (< 10000 ML per year)	0 - 20 ML discharged

Region

Metropolitan
 Level 3, NSW Govt Offices, 84 Crown Street
 WOLLONGONG NSW 2500
 Phone: 02 4224 4100
 Fax: 02 4224 4110
 PO Box 513 WOLLONGONG EAST
 NSW 2520

INFORMATION ABOUT THIS LICENCE.....	4
Dictionary.....	4
Responsibilities of licensee.....	4
Variation of licence conditions	4
Duration of licence	4
Licence review	4
Fees and annual return to be sent to the EPA.....	4
Transfer of licence	5
Public register and access to monitoring data	5
1 ADMINISTRATIVE CONDITIONS	5
A1 What the licence authorises and regulates	5
A2 Premises to which this licence applies	6
A3 Other activities	6
A4 Information supplied to the EPA.....	6
2 DISCHARGES TO AIR AND WATER AND APPLICATIONS TO LAND.....	6
P1 Location of monitoring/discharge points and areas.....	7
3 LIMIT CONDITIONS	7
L1 Pollution of waters.....	7
L2 Load limits	7
L3 Concentration limits.....	8
L4 Volume and mass limits	8
L5 Waste	9
L6 Noise Limits.....	9
L7 Odour	9
4 OPERATING CONDITIONS.....	9
O1 Activities must be carried out in a competent manner.....	9
O2 Maintenance of plant and equipment	10
O3 Biosolids at the premises must be stored, treated, processed, classified, transported and disposed	10
O4 Adequate notices, warning the public not to drink or otherwise use the treated effluent, must be	10
5 MONITORING AND RECORDING CONDITIONS	10
M1 Monitoring records.....	10
M2 Requirement to monitor concentration of pollutants discharged	11
M3 Testing methods - concentration limits.....	12
M4 Recording of pollution complaints	12
M5 Telephone complaints line.....	13
M6 Requirement to monitor volume or mass	13
M7 Laboratory Accreditation.....	14
6 REPORTING CONDITIONS.....	14
R1 Annual return documents	14

Environment Protection Licence



Licence - 10020

R2	Notification of environmental harm.....	15
R3	Written report	15
GENERAL CONDITIONS.....		16
G1	Copy of licence kept at the premises	16
POLLUTION STUDIES AND REDUCTION PROGRAMS		16
SPECIAL CONDITIONS.....		17
DICTIONARY		17
	General Dictionary	17

Information about this licence

Dictionary

A definition of terms used in the licence can be found in the dictionary at the end of this licence.

Responsibilities of licensee

Separate to the requirements of this licence, general obligations of licensees are set out in the Protection of the Environment Operations Act 1997 ("the Act") and the Regulations made under the Act. These include obligations to:

- ensure persons associated with you comply with this licence, as set out in section 64 of the Act;
- control the pollution of waters and the pollution of air (see for example sections 120 - 132 of the Act); and
- report incidents causing or threatening material environmental harm to the environment, as set out in Part 5.7 of the Act.

Variation of licence conditions

The licence holder can apply to vary the conditions of this licence. An application form for this purpose is available from the EPA.

The EPA may also vary the conditions of the licence at any time by written notice without an application being made.

Where a licence has been granted in relation to development which was assessed under the Environmental Planning and Assessment Act 1979 in accordance with the procedures applying to integrated development, the EPA may not impose conditions which are inconsistent with the development consent conditions until the licence is first reviewed under Part 3.6 of the Act.

Duration of licence

This licence will remain in force until the licence is surrendered by the licence holder or until it is suspended or revoked by the EPA or the Minister. A licence may only be surrendered with the written approval of the EPA.

Licence review

The Act requires that the EPA review your licence at least every 5 years after the issue of the licence, as set out in Part 3.6 and Schedule 5 of the Act. You will receive advance notice of the licence review.

Fees and annual return to be sent to the EPA

For each licence fee period you must pay:

- an administrative fee; and
- a load-based fee (if applicable).

The EPA publication "A Guide to Licensing" contains information about how to calculate your licence fees.

Environment Protection Licence

Licence - 10020



Environment,
Climate Change
& Water

The licence requires that an Annual Return, comprising a Statement of Compliance and a summary of any monitoring required by the licence (including the recording of complaints), be submitted to the EPA. The Annual Return must be submitted within 60 days after the end of each reporting period. See condition R1 regarding the Annual Return reporting requirements.

Usually the licence fee period is the same as the reporting period.

Transfer of licence

The licence holder can apply to transfer the licence to another person. An application form for this purpose is available from the EPA.

Public register and access to monitoring data

Part 9.5 of the Act requires the EPA to keep a public register of details and decisions of the EPA in relation to, for example:

- licence applications;
- licence conditions and variations;
- statements of compliance;
- load based licensing information; and
- load reduction agreements.

Under s320 of the Act application can be made to the EPA for access to monitoring data which has been submitted to the EPA by licensees.

This licence is issued to:

**SYDNEY OLYMPIC PARK AUTHORITY
LOCKED BAG 3, SYDNEY OLYMPIC PARK
HOMEBUSH BAY NSW 2127**

subject to the conditions which follow.

1 Administrative conditions

A1 What the licence authorises and regulates

A1.1 This licence regulates water pollution resulting from the activity/ies specified below carried out at the premises specified in A2.

Water Reclamation and Recycling Scheme



A1.2 Not applicable.

A1.3 Not applicable.

A2 Premises to which this licence applies

A2.1 The licence applies to the following premises:

Premises Details
SYDNEY OLYMPIC PARK
Marjorie Jackson Parkway, Edwin Flack Avenue
 HOMEBUSH BAY
NSW
2127
LOT 5005 DP 1004785; PART LOT 6002 DP 1063407

A3 Other activities

A3.1 Not applicable.

A4 Information supplied to the EPA

A4.1 Works and activities must be carried out in accordance with the proposal contained in the licence application, except as expressly provided by a condition of this licence.

In this condition the reference to "the licence application" includes a reference to:

- (a) the applications for any licences (including former pollution control approvals) which this licence replaces under the Protection of the Environment Operations (Savings and Transitional) Regulation 1998; and
- (b) the licence information form provided by the licensee to the EPA to assist the EPA in connection with the issuing of this licence.

2 Discharges to air and water and applications to land

Licence - 10020

P1 Location of monitoring/discharge points and areas

P1.1 Not applicable.

P1.2 The following points referred to in the table are identified in this licence for the purposes of the monitoring and/or the setting of limits for discharges of pollutants to water from the point.

P1.3 The following utilisation areas referred to in the table below are identified in this licence for the purposes of the monitoring and/or the setting of limits for any application of solids or liquids to the utilisation area.

Water and land

EPA identification no.	Type of monitoring point	Type of discharge point	Description of location
1	Surplus saline discharge from brickpit	Surplus saline discharge from brickpit	End of pipe from brickpit near footbridge over tributary of Haslams Creek.
2	Overflow discharge from Eastern Water Quality Control Pond	Overflow discharge from Eastern Water Quality Control Pond	Weir in gabion wall at the discharge end of the Eastern Water Quality Control Pond
3	Discharge of reverse osmosis backwash water	Discharge of reverse osmosis backwash water	Submerged approximately 3m from edge of embankment of Haslams Creek as described by Map titled" Sydney Olympic Park RO Discharge Plan Drawing No. 001-P-P-0687 Rev B dated 28/8/06"

3 Limit conditions**L1 Pollution of waters**

L1.1 Except as may be expressly provided in any other condition of this licence, the licensee must comply with section 120 of the Protection of the Environment Operations Act 1997.

L2 Load limits

L2.1 Not applicable.

L2.2 Not applicable.

Licence - 10020

L3 Concentration limits

- L3.1 For each monitoring/discharge point or utilisation area specified in the table\& below (by a point number), the concentration of a pollutant discharged at that point, or applied to that area, must not exceed the concentration limits specified for that pollutant in the table.
- L3.2 Where a pH quality limit is specified in the table, the specified percentage of samples must be within the specified ranges.
- L3.3 To avoid any doubt, this condition does not authorise the pollution of waters by any pollutant other than those specified in the table\&.

Water and Land

POINT 2

Pollutant	Units of Measure	50 percentile concentration limit	90 percentile concentration limit	80 percentile concentration limit	100 percentile Concentration Limit
Chlorine	milligrams per litre				0.5
Oil and Grease	milligrams per litre				10
pH	milligrams per litre				6.5-8
Nitrogen (total)	milligrams per litre		10		12
Phosphorus (total)	milligrams per litre				1
Faecal Coliforms	colony forming units per 100 millilitres			1000	4000
BOD	milligrams per litre				20
Total suspended solids	milligrams per litre		40		50

L4 Volume and mass limits

- L4.1 For each discharge point or utilisation area specified below (by a point number), the volume/mass of:
- (a) liquids discharged to water; or;
 - (b) solids or liquids applied to the area;
- must not exceed the volume/mass limit specified for that discharge point or area.

Point	Unit of measure	Volume/Mass Limit
1	kilolitres per day	1000
2	kilolitres per day	7000

L4.2 In the above volume and mass limit table (condition L4.1) the unit of measure for discharge point 2 is kilolitres per day for a maximum continuous period of 30 days.

L5 Waste

L5.1 The licensee must not cause, permit or allow any waste generated outside the premises to be received at the premises for storage, treatment, processing, reprocessing or disposal or any waste generated at the premises to be disposed of at the premises, except sewage and waste waters described in the Licence application.

L6 Noise Limits

L6.1 Noise from the Water Reclamation Plant must not exceed:

- (a) an L_{A10} (15 minute) noise emission criterion of 44dB(A) during the day (7am to 10pm) at the Olympic Village and;
- (b) an L_{A10} (15 minute) noise emission criterion of 30dB(A) during the night (10pm to 7am) at the Olympic Village.

Noise emissions from the operation of the Water Treatment Plant must not exceed:

- (a) an L_{A10} (15 minute) noise emission criterion of 30dB(A) at any time at the frog habitat areas.

L7 Odour

L7.1 The Licensee must not allow the emission of offensive odours from the premises.

4 Operating conditions

O1 Activities must be carried out in a competent manner

O1.1 Licensed activities must be carried out in a competent manner.

This includes:

- (a) the processing, handling, movement and storage of materials and substances used to carry out the activity; and
- (b) the treatment, storage, processing, reprocessing, transport and disposal of waste generated by the activity.

O2 Maintenance of plant and equipment

O2.1 All plant and equipment installed at the premises or used in connection with the licensed activity:
(a) must be maintained in a proper and efficient condition; and
(b) must be operated in a proper and efficient manner.

O2.2 Note: For guidance refer to the National Water Quality Management Strategy: Guidelines for Sewage Systems - Reclaimed Water 2000

O3 Biosolids at the premises must be stored, treated, processed, classified, transported and disposed in accordance with the Biosolids Guideline.

Note: This condition does not apply to the reuse or disposal of biosolids by the licensee at locations other than the premises.

O4 Adequate notices, warning the public not to drink or otherwise use the treated effluent, must be erected on the site. These notices must be legible English and in any other languages as may be necessary, and must indicate at least that the water in use is "Reclaimed Water - Unfit for Drinking".

5 Monitoring and recording conditions

M1 Monitoring records

M1.1 The results of any monitoring required to be conducted by this licence or a load calculation protocol must be recorded and retained as set out in this condition.

M1.2 All records required to be kept by this licence must be:

- (a) in a legible form, or in a form that can readily be reduced to a legible form;
- (b) kept for at least 4 years after the monitoring or event to which they relate took place; and
- (c) produced in a legible form to any authorised officer of the EPA who asks to see them.

M1.3 The following records must be kept in respect of any samples required to be collected for the purposes of this licence:

- (a) the date(s) on which the sample was taken;
- (b) the time(s) at which the sample was collected;
- (c) the point at which the sample was taken; and
- (d) the name of the person who collected the sample.

M2 Requirement to monitor concentration of pollutants discharged

M2.1 For each monitoring/discharge point or utilisation area specified below (by a point number), the licensee must monitor (by sampling and obtaining results by analysis) the concentration of each pollutant specified in Column 1. The licensee must use the sampling method, units of measure, and sample at the frequency, specified opposite in the other columns:

*Water and Land***POINT 1**

Pollutant	Units of measure	Frequency	Sampling Method
Salinity	millisiemens per centimetre	Daily during any discharge	Flow meter and continuous logger

POINT 2

Pollutant	Units of measure	Frequency	Sampling Method
BOD	milligrams per litre	Daily during any discharge	Grab sample
Chlorine	milligrams per litre	Daily during any discharge	Grab sample
Faecal Coliforms	colony forming units per 100 millilitres	Daily during any discharge	Grab sample
Nitrogen (total)	milligrams per litre	Daily during any discharge	Grab sample
Oil and Grease	milligrams per litre	Daily during any discharge	Grab sample
Phosphorus (total)	milligrams per litre	Daily during any discharge	Grab sample
Total suspended solids	milligrams per litre	Daily during any discharge	Grab sample
pH	pH	Daily during any discharge	Grab sample

Licence - 10020

POINT 3

Pollutant	Units of measure	Frequency	Sampling Method
Aluminium	milligrams per litre	Monthly	Grab sample
Ammonia	milligrams per litre	Monthly	Grab sample
BOD	milligrams per litre	Monthly	Grab sample
Boron	milligrams per litre	Monthly	Grab sample
Conductivity	microsiemens per centimetre	Monthly	Grab sample
Copper	milligrams per litre	Monthly	Grab sample
Manganese	milligrams per litre	Monthly	Grab sample
Nitrate + nitrite (oxidised nitrogen)	milligrams per litre	Monthly	Grab sample
Oil and Grease	milligrams per litre	Monthly	Grab sample
Orthophosphate	milligrams per litre	Monthly	Grab sample
Reactive Phosphorus	milligrams per litre	Monthly	Grab sample
Sulfate	milligrams per litre	Monthly	Grab sample
Total Kjeldahl Nitrogen	milligrams per litre	Monthly	Grab sample
Total Phosphorus - unfiltered sample	milligrams per litre	Monthly	Grab sample
Total suspended solids	milligrams per litre	Monthly	Grab sample
Zinc	milligrams per litre	Monthly	Grab sample

M3 Testing methods - concentration limits

M3.1 Not applicable.

M3.2 Subject to any express provision to the contrary in this licence, monitoring for the concentration of a pollutant discharged to waters or applied to a utilisation area must be done in accordance with the Approved Methods Publication unless another method has been approved by the EPA in writing before any tests are conducted.

M4 Recording of pollution complaints

M4.1 The licensee must keep a legible record of all complaints made to the licensee or any employee or agent of the licensee in relation to pollution arising from any activity to which this licence applies.

M4.2 The record must include details of the following:

- the date and time of the complaint;
- the method by which the complaint was made;

Licence - 10020

- (c) any personal details of the complainant which were provided by the complainant or, if no such details were provided, a note to that effect;
- (d) the nature of the complaint;
- (e) the action taken by the licensee in relation to the complaint, including any follow-up contact with the complainant; and
- (f) if no action was taken by the licensee, the reasons why no action was taken.

M4.3 The record of a complaint must be kept for at least 4 years after the complaint was made.

M4.4 The record must be produced to any authorised officer of the EPA who asks to see them.

M5 Telephone complaints line

M5.1 The licensee must operate during its operating hours a telephone complaints line for the purpose of receiving any complaints from members of the public in relation to activities conducted at the premises or by the vehicle or mobile plant, unless otherwise specified in the licence.

M5.2 The licensee must notify the public of the complaints line telephone number and the fact that it is a complaints line so that the impacted community knows how to make a complaint.

M5.3 Conditions M5.1 and M5.2 do not apply until 3 months after:

- (a) the date of the issue of this licence or
- (b) if this licence is a replacement licence within the meaning of the Protection of the Environment Operations (Savings and Transitional) Regulation 1998, the date on which a copy of the licence was served on the licensee under clause 10 of that regulation.

M6 Requirement to monitor volume or mass

M6.1 For each discharge point or utilisation area specified below, the licensee must monitor:

- (a) the volume of liquids discharged to water or applied to the area;
- (b) the mass of solids applied to the area;
- (c) the mass of pollutants emitted to the air;

at the frequency and using the method and units of measure, specified below.

POINT 1

Frequency	Unit Of Measure	Sampling Method
Daily during any discharge	kilolitres per day	Method approved in writing by the Authority

POINT 2

Frequency	Unit Of Measure	Sampling Method
Daily during any discharge	kilolitres per day	Method approved in writing by the Authority

M7 Laboratory Accreditation

M7.1 Samples taken pursuant to a requirement in this licence to monitor the volume, mass or concentration of pollutants, must be analysed and reported in accordance with the laboratory accreditation requirements set out in section 2.1.3 of the Load Calculation Protocol. The Load Calculation Protocol is the Protocol referred to in clause 18 of the Protection of the Environment Operations (General) Regulation 1998. A copy of the Protocol was published in the Government Gazette on 25 June 1999 and can be purchased from the EPA or viewed at <http://www.epa.nsw.gov.au>.

6 Reporting conditions

R1 Annual return documents

What documents must an Annual Return contain?

R1.1 The licensee must complete and supply to the EPA an Annual Return in the approved form comprising:

- (a) a Statement of Compliance; and
- (b) a Monitoring and Complaints Summary.

A copy of the form in which the Annual Return must be supplied to the EPA accompanies this licence. Before the end of each reporting period, the EPA will provide to the licensee a copy of the form that must be completed and returned to the EPA.

Period covered by Annual Return

R1.2 An Annual Return must be prepared in respect of each reporting period, except as provided below.

Note: The term "reporting period" is defined in the dictionary at the end of this licence. Do not complete the Annual Return until after the end of the reporting period.

R1.3 Where this licence is transferred from the licensee to a new licensee:

- (a) the transferring licensee must prepare an Annual Return for the period commencing on the first day of the reporting period and ending on the date the application for the transfer of the licence to the new licensee is granted; and
- (b) the new licensee must prepare an Annual Return for the period commencing on the date the application for the transfer of the licence is granted and ending on the last day of the reporting period.

Note: An application to transfer a licence must be made in the approved form for this purpose.

R1.4 Where this licence is surrendered by the licensee or revoked by the EPA or Minister, the licensee must prepare an Annual Return in respect of the period commencing on the first day of the reporting period and ending on:

Environment Protection Licence



Licence - 10020

- (a) in relation to the surrender of a licence - the date when notice in writing of approval of the surrender is given; or
- (b) in relation to the revocation of the licence - the date from which notice revoking the licence operates.

Deadline for Annual Return

R1.5 The Annual Return for the reporting period must be supplied to the EPA by registered post not later than 60 days after the end of each reporting period or in the case of a transferring licence not later than 60 days after the date the transfer was granted (the 'due date').

Notification where actual load can not be calculated

R1.6 Not applicable.

Licensee must retain copy of Annual Return

R1.7 The licensee must retain a copy of the Annual Return supplied to the EPA for a period of at least 4 years after the Annual Return was due to be supplied to the EPA.

Certifying of Statement of Compliance and signing of Monitoring and Complaints Summary

R1.8 Within the Annual Return, the Statement of Compliance must be certified and the Monitoring and Complaints Summary must be signed by:
(a) the licence holder; or
(b) by a person approved in writing by the EPA to sign on behalf of the licence holder.

R1.9 A person who has been given written approval to certify a certificate of compliance under a licence issued under the Pollution Control Act 1970 is taken to be approved for the purpose of this condition until the date of first review of this licence.

R2 Notification of environmental harm

Note: The licensee or its employees must notify the EPA of incidents causing or threatening material harm to the environment as soon as practicable after the person becomes aware of the incident in accordance with the requirements of Part 5.7 of the Act.

R2.1 Notifications must be made by telephoning the Environment Line service on 131 555.

R2.2 The licensee must provide written details of the notification to the EPA within 7 days of the date on which the incident occurred.

R3 Written report

R3.1 Where an authorised officer of the EPA suspects on reasonable grounds that:
(a) where this licence applies to premises, an event has occurred at the premises; or

Licence - 10020

(b) where this licence applies to vehicles or mobile plant, an event has occurred in connection with the carrying out of the activities authorised by this licence, and the event has caused, is causing or is likely to cause material harm to the environment (whether the harm occurs on or off premises to which the licence applies), the authorised officer may request a written report of the event.

R3.2 The licensee must make all reasonable inquiries in relation to the event and supply the report to the EPA within such time as may be specified in the request.

R3.3 The request may require a report which includes any or all of the following information:

- (a) the cause, time and duration of the event;
- (b) the type, volume and concentration of every pollutant discharged as a result of the event;
- (c) the name, address and business hours telephone number of employees or agents of the licensee, or a specified class of them, who witnessed the event;
- (d) the name, address and business hours telephone number of every other person (of whom the licensee is aware) who witnessed the event, unless the licensee has been unable to obtain that information after making reasonable effort;
- (e) action taken by the licensee in relation to the event, including any follow-up contact with any complainants;
- (f) details of any measure taken or proposed to be taken to prevent or mitigate against a recurrence of such an event; and
- (g) any other relevant matters.

R3.4 The EPA may make a written request for further details in relation to any of the above matters if it is not satisfied with the report provided by the licensee. The licensee must provide such further details to the EPA within the time specified in the request.

General conditions

G1 Copy of licence kept at the premises

G1.1 A copy of this licence must be kept at the premises to which the licence applies.

G1.2 The licence must be produced to any authorised officer of the EPA who asks to see it.

G1.3 The licence must be available for inspection by any employee or agent of the licensee working at the premises.

Pollution studies and reduction programs

Special conditions

Dictionary

General Dictionary

In this licence, unless the contrary is indicated, the terms below have the following meanings:

3DGM [in relation to a concentration limit]	Means the three day geometric mean, which is calculated by multiplying the results of the analysis of three samples collected on consecutive days and then taking the cubed root of that amount. Where one or more of the samples is zero or below the detection limit for the analysis, then 1 or the detection limit respectively should be used in place of those samples
Act	Means the Protection of the Environment Operations Act 1997
activity	Means a scheduled or non-scheduled activity within the meaning of the Protection of the Environment Operations Act 1997
actual load	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 1998
AM	Together with a number, means an ambient air monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
AMG	Australian Map Grid
anniversary date	The anniversary date is the anniversary each year of the date of issue of the licence. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
annual return	Is defined in R1.1
Approved Methods Publication	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 1998
assessable pollutants	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 1998
BOD	Means biochemical oxygen demand
CEM	Together with a number, means a continuous emission monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
COD	Means chemical oxygen demand
composite sample	Unless otherwise specifically approved in writing by the EPA, a sample consisting of 24 individual samples collected at hourly intervals and each having an equivalent volume.
cond.	Means conductivity
environment	Has the same meaning as in the Protection of the Environment Operations Act 1997
environment protection legislation	Has the same meaning as in the Protection of the Environment Administration Act 1991
EPA	Means Environment Protection Authority of New South Wales.

Licence - 10020

fee-based activity classification	Means the numbered short descriptions in Schedule 1 of the Protection of the Environment Operations (General) Regulation 1998.
flow weighted composite sample	Means a sample whose composites are sized in proportion to the flow at each composites time of collection.
general solid waste (non-putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
general solid waste (putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
grab sample	Means a single sample taken at a point at a single time
hazardous waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
licensee	Means the licence holder described at the front of this licence
load calculation protocol	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 1998
local authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
material harm	Has the same meaning as in section 147 Protection of the Environment Operations Act 1997
MBAS	Means methylene blue active substances
Minister	Means the Minister administering the Protection of the Environment Operations Act 1997
mobile plant	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
motor vehicle	Has the same meaning as in the Protection of the Environment Operations Act 1997
Noise	Means "sound pressure levels" for the purposes of conditions under L6 of this licence
Noise sensitive locations	Means buildings used as residence, hospital, school, child care centre, places of public worship and nursing homes. A noise sensitive location includes the land within 30 metres of the building
NSW Industrial Noise Policy	Means the document titled "NSW Industrial Noise Policy" published by the Environment Protection Authority in January 2000
O&G	Means oil and grease
percentile [in relation to a concentration limit of a sample]	Means that percentage [eg.50%] of the number of samples taken that must meet the concentration limit specified in the licence for that pollutant over a specified period of time. In this licence, the specified period of time is the Reporting Period unless otherwise stated in this licence.
plant	Includes all plant within the meaning of the Protection of the Environment Operations Act 1997 as well as motor vehicles.
pollution of waters [or water pollution]	Has the same meaning as in the Protection of the Environment Operations Act 1997
premises	Means the premises described in condition A2.1
public authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
regional office	Means the relevant EPA office referred to in the Contacting the EPA document accompanying this licence
reporting period	For the purposes of this licence, the reporting period means the period of 12 months after the issue of the licence, and each subsequent period of 12 months. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary

Licence - 10020

	of the date of issue or last renewal of the licence following the commencement of the Act.
restricted solid waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
scheduled activity	Means an activity listed in Schedule 1 of the Protection of the Environment Operations Act 1997
special waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
TM	Together with a number, means a test method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
TSP	Means total suspended particles
TSS	Means total suspended solids
Type 1 substance	Means the elements antimony, arsenic, cadmium, lead or mercury or any compound containing one or more of those elements
Type 2 substance	Means the elements beryllium, chromium, cobalt, manganese, nickel, selenium, tin or vanadium or any compound containing one or more of those elements
utilisation area	Means any area shown as a utilisation area on a map submitted with the application for this licence
waste	Has the same meaning as in the Protection of the Environment Operations Act 1997
waste type	Means liquid, restricted solid waste, general solid waste (putrescible), general solid waste (non-putrescible), special waste or hazardous waste

Mr Peter Yates

Environment Protection Authority

(By Delegation)

Date of this edition - 02-Jan-2009

End Notes

- 1 Licence varied by notice V/M upgrade, issued on 07-Jul-2000, which came into effect on 07-Jul-2000.
- 2 Licence varied by notice 10020, issued on 20-Jan-2000, which came into effect on 14-Feb-2000.



Licence - 10020

End Notes

- | | |
|---|--|
| 3 | Licence varied by notice 1039389, issued on 16-Dec-2004, which came into effect on 10-Jan-2005. |
| 4 | Licence varied by notice 1063016, issued on 01-Sep-2006, which came into effect on 01-Sep-2006. |
| 5 | Condition A1.3 Not applicable varied by notice issued on <issue date> which came into effect on <effective date> |
| 6 | Licence fee period changed by notice 1096498 approved on . |