

# Environment Protection Licence

Licence - 13042



## Licence Details

Number:	13042
Anniversary Date:	14-May

## Licensee

MIDCOAST COUNTY COUNCIL  
 PO BOX 671  
 TAREE NSW 2430

## Premises

STROUD WASTEWATER TREATMENT PLANT  
 OFF SIMMSVILLE ROAD  
 STROUD NSW 2425

## Scheduled Activity

Sewage Treatment

## Fee Based Activity

## Scale

Sewage treatment processing by small plants

> 100-219 ML discharged

## Region

Hunter  
 Ground Floor, NSW Govt Offices, 117 Bull Street  
 NEWCASTLE WEST NSW 2302  
 Phone: 02 4908 6800  
 Fax: 02 4908 6810  
 PO Box 488G NEWCASTLE  
 NSW 2300

# Environment Protection Licence

Licence - 13042



<b>INFORMATION ABOUT THIS LICENCE</b>	4
Dictionary	4
Responsibilities of licensee	4
Duration of licence	4
Licence review	4
Fees and annual return to be sent to the EPA	4
Transfer of licence	5
Public register and access to monitoring data	5
<b>1 ADMINISTRATIVE CONDITIONS</b>	6
A1 What the licence authorises and regulates	6
A2 Premises or plant to which this licence applies	6
A3 Information supplied to the EPA	6
<b>2 DISCHARGES TO AIR AND WATER AND APPLICATIONS TO LAND</b>	7
P1 Location of monitoring/discharge points and areas	7
<b>3 LIMIT CONDITIONS</b>	7
L1 Pollution of waters	7
L2 Load limits	8
L3 Concentration limits	8
L4 Volume and mass limits	9
L5 Waste	9
L6 Potentially offensive odour	10
<b>4 OPERATING CONDITIONS</b>	10
O1 Activities must be carried out in a competent manner	10
O2 Maintenance of plant and equipment	10
O3 Emergency response	10
O4 Processes and management	11
O5 Other operating conditions	11
<b>5 MONITORING AND RECORDING CONDITIONS</b>	11
M1 Monitoring records	11
M2 Requirement to monitor concentration of pollutants discharged	12
M3 Testing methods - concentration limits	12
M4 Recording of pollution complaints	13
M5 Telephone complaints line	13
M6 Requirement to monitor volume or mass	13
M7 Requirement to record overflow or bypass incidents	14

# Environment Protection Licence

Licence - 13042



M8	Other monitoring and recording conditions	14
<b>6</b>	<b>REPORTING CONDITIONS</b>	<b>15</b>
R1	Annual return documents	15
R2	Notification of environmental harm	16
R3	Written report	16
R4	Notification of bypass or overflow incidents	17
R5	Annual system performance report	17
<b>7</b>	<b>GENERAL CONDITIONS</b>	<b>18</b>
G1	Copy of licence kept at the premises or plant	18
G2	Contact number for incidents and responsible employees	18
G3	Signage	18
<b>DICTIONARY</b>		<b>19</b>
	General Dictionary	19

# Environment Protection Licence

Licence - 13042



## Information about this licence

### Dictionary

A definition of terms used in the licence can be found in the dictionary at the end of this licence.

### Responsibilities of licensee

Separate to the requirements of this licence, general obligations of licensees are set out in the Protection of the Environment Operations Act 1997 ("the Act") and the Regulations made under the Act. These include obligations to:

- ensure persons associated with you comply with this licence, as set out in section 64 of the Act;
- control the pollution of waters and the pollution of air (see for example sections 120 - 132 of the Act); and
- report incidents causing or threatening material environmental harm to the environment, as set out in Part 5.7 of the Act.

### Variation of licence conditions

The licence holder can apply to vary the conditions of this licence. An application form for this purpose is available from the EPA.

The EPA may also vary the conditions of the licence at any time by written notice without an application being made.

Where a licence has been granted in relation to development which was assessed under the Environmental Planning and Assessment Act 1979 in accordance with the procedures applying to integrated development, the EPA may not impose conditions which are inconsistent with the development consent conditions until the licence is first reviewed under Part 3.6 of the Act.

### Duration of licence

This licence will remain in force until the licence is surrendered by the licence holder or until it is suspended or revoked by the EPA or the Minister. A licence may only be surrendered with the written approval of the EPA.

### Licence review

The Act requires that the EPA review your licence at least every 5 years after the issue of the licence, as set out in Part 3.6 and Schedule 5 of the Act. You will receive advance notice of the licence review.

### Fees and annual return to be sent to the EPA

For each licence fee period you must pay:

- an administrative fee; and
- a load-based fee (if applicable).

# Environment Protection Licence

Licence - 13042



The EPA publication "A Guide to Licensing" contains information about how to calculate your licence fees. The licence requires that an Annual Return, comprising a Statement of Compliance and a summary of any monitoring required by the licence (including the recording of complaints), be submitted to the EPA. The Annual Return must be submitted within 60 days after the end of each reporting period. See condition R1 regarding the Annual Return reporting requirements.

Usually the licence fee period is the same as the reporting period.

## Transfer of licence

The licence holder can apply to transfer the licence to another person. An application form for this purpose is available from the EPA.

## Public register and access to monitoring data

Part 9.5 of the Act requires the EPA to keep a public register of details and decisions of the EPA in relation to, for example:

- licence applications;
- licence conditions and variations;
- statements of compliance;
- load based licensing information; and
- load reduction agreements.

Under s320 of the Act application can be made to the EPA for access to monitoring data which has been submitted to the EPA by licensees.

## This licence is issued to:

<b>MIDCOAST COUNTY COUNCIL</b>
<b>PO BOX 671</b>
<b>TAREE NSW 2430</b>

subject to the conditions which follow.

# Environment Protection Licence

Licence - 13042



## 1 Administrative Conditions

### A1 What the licence authorises and regulates

A1.1 This licence regulates water pollution resulting from the activity/ies specified below carried out at the premises specified in A2.

<b>Fee Based Activity</b>	<b>Scale</b>
Sewage treatment processing by small plants	> 100-219 ML discharged

A1.2 The objectives of this licence are to:

- require practical measures to be taken to protect the environment and public health;
- require proper and efficient design, construction and management of the sewage treatment system to minimise harm to public health and the environment; and
- minimise the frequency and volume of overflows from the reticulation system and sewage treatment plant.

A1.3 This licence is to be construed in a manner that will promote the objectives referred to above.

### A2 Premises or plant to which this licence applies

A2.1 The licence applies to the following premises:

<b>Premises Details</b>
<b>STROUD WASTEWATER TREATMENT PLANT</b>
<b>OFF SIMMSVILLE ROAD</b>
<b>STROUD</b>
<b>NSW 2425</b>
<b>LOT 1 DP 1036662</b>
<b>SHOWN ON MAP "STROUD STP - DETAIL DESIGN GENERAL" SUBMITTED WITH LICENCE APPLICATION 9 FEBRUARY 2009 WHICH IS FILED ON EPA FILE LIC09/154.</b>

### A3 Information supplied to the EPA

A3.1 Works and activities must be carried out in accordance with the proposal contained in the licence application, except as expressly provided by a condition of this licence.

In this condition the reference to "the licence application" includes a reference to:

- the applications for any licences (including former pollution control approvals) which this licence replaces under the Protection of the Environment Operations (Savings and Transitional) Regulation 1998; and
- the licence information form provided by the licensee to the EPA to assist the EPA in connection with the issuing of this licence.

# Environment Protection Licence

Licence - 13042



## 2 Discharges to Air and Water and Applications to Land

### P1 Location of monitoring/discharge points and areas

P1.1 The following points referred to in the table are identified in this licence for the purposes of the monitoring and/or the setting of limits for discharges of pollutants to water from the point.

P1.2 The following utilisation areas referred to in the table below are identified in this licence for the purposes of the monitoring and/or the setting of limits for any application of solids or liquids to the utilisation area.

#### *Water and land*

EPA Identification no.	Type of Monitoring Point	Type of Discharge Point	Location Description
1		Discharge to waters	Greens Crossing in Karuah River marked as Discharge Point No 1 on map "Stroud Sewerage Scheme Location of Discharge Points" submitted with Licence Application dated 13/02/09 which is filed on EPA file LIC09/154.
2	Effluent quality monitoring Volume monitoring		Immediately after Booster Pump Station at the WWTP premises as shown on map "Stroud STP Detail Design" submitted with Licence Application Information dated 13/02/09, which is filed on EPA file LIC09/154.
3	Volume monitoring		Pipeline to effluent reuse area as shown on map "Stroud STP Detail Design" submitted with Licence Application Information dated 13/02/09, which is filed on EPA file LIC09/154.
4	Ambient water monitoring		Karuah River approximately 1600 m upstream of EPA identification point 1, submitted as additional information dated 23/3/09 which is filed on EPA file LIC09/154.
5	Ambient water monitoring		Karuah River approximately 700 m downstream of EPA identification Point 1, submitted as additional information dated 23/3/09 which is filed on EPA file LIC09/154.

## 3 Limit Conditions

### L1 Pollution of waters

L1.1 Except as may be expressly provided in any other condition of this licence, the licensee must comply with section 120 of the Protection of the Environment Operations Act 1997.

# Environment Protection Licence

Licence - 13042



## L2 Load limits

- L2.1 The total load of phosphorus discharged via EPA identification discharge point 1 must not exceed 24 kg/yr based on a rolling average over 5 years.

Note: The Environmental Impact Statement for the Stroud WWTP found that a sustainable target load for total phosphorus discharge to the Karuah River is 24 kg/yr averaged over 5 years.

## L3 Concentration limits

- L3.1 For each monitoring/discharge point or utilisation area specified in the table\ below (by a point number), the concentration of a pollutant discharged at that point, or applied to that area, must not exceed the concentration limits specified for that pollutant in the table.
- L3.2 Where a pH quality limit is specified in the table, the specified percentage of samples must be within the specified ranges.
- L3.3 To avoid any doubt, this condition does not authorise the pollution of waters by any pollutant other than those specified in the table\.
- L3.4 Water and/or Land Concentration Limits

### POINT 1

Pollutant	Units of Measure	50 percentile concentration limit	90 percentile concentration limit	3DGM concentration limit	100 percentile concentration limit
Ammonia	milligrams per litre				2.0
BOD	milligrams per litre		10		15
Faecal Coliforms	colony forming units per 100 millilitres		200		600
Nitrogen (total)	milligrams per litre				10
Oil and Grease	milligrams per litre		7		10
pH	pH				6.5-8.5
Phosphorus (total)	milligrams per litre				4.4
TSS	milligrams per litre		15		20

Note:



# Environment Protection Licence

Licence - 13042



The limits above relate to the discharge to the Karuah River from Point 1. Determining compliance with these limits is achieved by sampling waters at identification point 2.

## L4 Volume and mass limits

L4.1 For each discharge point or utilisation area specified below (by a point number), the volume/mass of:

a) liquids discharged to water; or;

b) solids or liquids applied to the area;

must not exceed the volume/mass limit specified for that discharge point or area.

Point	Unit of Measure	Volume/Mass Limit
1	kilolitres per day	2000

Note:

The volume limit above relates to the discharge to the Karuah River from Point 1. Determining compliance with this limit is achieved by measuring the flow at identification Point 2.

## L4.2 Discharge to the Karuah River

River discharges via EPA discharge point 1 must only occur under the following conditions;

(a) When the River has a flow greater than 2,000 ML/day as measured at the Booral Gauging Station;

(b) When the effluent storage ponds are at greater than 50% capacity; and

(c) At a maximum discharge rate of 2 ML/day;

or as otherwise approved by the EPA.

## L5 Waste

L5.1 The licensee must not cause, permit or allow any waste generated outside the premises to be received at the premises for storage, treatment, processing, reprocessing or disposal or any waste generated at the premises to be disposed of at the premises, except as expressly permitted by the licence.

L5.2 This condition only applies to the storage, treatment, processing, reprocessing or disposal of waste at the premises if those activities require an environment protection licence.

L5.3 The licensee may receive and/or transfer sewage and liquid waste generated outside the premises for treatment, processing or reprocessing at the premises. The licensee must take reasonable steps to ensure that sewage received at the premises has been lawfully discharged in accordance with a trade waste agreement or customer contract (as applicable) in force between the licensee and the generator of the waste. The licensee must treat, process or reprocess the sewage and liquid waste in accordance with this licence prior to discharge from the premises.

# Environment Protection Licence

Licence - 13042



L5.4 The licensee may receive, store, treat, process or reprocess and/or transfer at the premises sewage products generated or stored outside the premises by the licensee's other sewage treatment systems. Sewage products must be received, treated, processed or reprocessed in accordance with this licence.

## **L6 Potentially offensive odour**

L6.1 No condition of this licence identifies a potentially offensive odour for the purposes of Section 129 of the Protection of the Environment Operations Act 1997.

L6.2 The licensee must not cause or permit the emission of offensive odour beyond the boundary of the premises.

Note: Section 129 of the Protection of the Environment Operations Act 1997, provides that the licensee must not cause or permit the emission of any offensive odour from the premises but provides a defence if the emission is identified in the relevant environment protection licence as a potentially offensive odour and the odour was emitted in accordance with the conditions of a licence directed at minimising odour.

## **4 Operating Conditions**

### **O1 Activities must be carried out in a competent manner**

O1.1 Licensed activities must be carried out in a competent manner.

This includes:

- a) the processing, handling, movement and storage of materials and substances used to carry out the activity; and
- b) the treatment, storage, processing, reprocessing, transport and disposal of waste generated by the activity.

Note: The requirements of O1.1 apply to the whole of the premises, including the reticulation system.

### **O2 Maintenance of plant and equipment**

O2.1 All plant and equipment installed at the premises or used in connection with the licensed activity:

- a) must be maintained in a proper and efficient condition; and
- b) must be operated in a proper and efficient manner.

Note: The requirements of O2.1 apply to the whole of the premises, including the reticulation system.

### **O3 Emergency response**

O3.1 In the event of an overflow or bypass that harms or is likely to harm the environment, the licensee must use all practicable measures to minimise the impact of the overflow or bypass on the environment and public health. These measures are to be implemented as soon as practical after

# Environment Protection Licence

Licence - 13042



the licensee or one of the licensee's employees or agents becomes aware of the overflow or bypass.

## O4 Processes and management

O4.1 The licensee must ensure that any extensions to the reticulation system after January 2004 are planned, designed, constructed and installed to prevent as far as practicable overflows from the premises.

Note: "The premises" includes both the new and the previously existing parts of the sewage treatment system.

## O5 Other operating conditions

O5.1 Sewage or effluent must not be discharged from identification points 1 and 2 unless it has been treated in accordance with the requirements of the Table below. The flows noted in the Table below are the inflows to the premises sewage treatment plants(s).

Required Treatment Process	Flow Range
Screening, grit removal, clarification, chemical treatment, activated sludge treatment, filtration, UV disinfection.	All liquid waste inflow unless the discharge from identification point 1 meets licence concentration limits.

O5.2 Effluent disposal management must be preferentially by sustainable effluent irrigation.

O5.3 Biosolids at the premises must be stored, treated, processed, classified, transported and disposed of in accordance with the Biosolids Guidelines, or as otherwise approved in writing by the EPA.

O5.4 The licensee must not consent to the receipt of organochlorine pesticides (including dieldrin, heptachlor and chlordane) into the sewage treatment system.

O5.5 Dry weather overflows resulting in pollution of waters from any sewage pumping station(s) installed within the sewage treatment system after January 2004 are not permitted.

## 5 Monitoring and Recording Conditions

### M1 Monitoring records

M1.1 The results of any monitoring required to be conducted by this licence or a load calculation protocol must be recorded and retained as set out in this condition.

M1.2 All records required to be kept by this licence must be:

- in a legible form, or in a form that can readily be reduced to a legible form;
- kept for at least 4 years after the monitoring or event to which they relate took place; and
- produced in a legible form to any authorised officer of the EPA who asks to see them.

# Environment Protection Licence

Licence - 13042



M1.3 The following records must be kept in respect of any samples required to be collected for the purposes of this licence:

- the date(s) on which the sample was taken;
- the time(s) at which the sample was collected;
- the point at which the sample was taken; and
- the name of the person who collected the sample.

## M2 Requirement to monitor concentration of pollutants discharged

M2.1 For each monitoring/discharge point or utilisation area specified below (by a point number), the licensee must monitor (by sampling and obtaining results by analysis) the concentration of each pollutant specified in Column 1. The licensee must use the sampling method, units of measure, and sample at the frequency, specified opposite in the other columns:

M2.2 Water and/ or Land Monitoring Requirements

### POINT 2

Pollutant	Units of measure	Frequency	Sampling Method
BOD	milligrams per litre	Monthly	Grab sample
Nitrogen (ammonia)	milligrams per litre	Monthly	Grab sample
Nitrogen (total)	milligrams per litre	Monthly	Grab sample
Oil and Grease	milligrams per litre	Monthly	Grab sample
pH	pH	Monthly	Grab sample
Phosphorus	milligrams per litre	Monthly	Grab sample
Phosphorus (total)	Kilograms per year	Yearly	Special Method 1
Total suspended solids	milligrams per litre	Monthly	Grab sample

### POINT 4,5

Pollutant	Units of measure	Frequency	Sampling Method
Faecal Coliforms	colony forming units per 100 millilitres	Quarterly during discharge	Grab sample
Nitrogen (total)	milligrams per litre	Quarterly during discharge	Grab sample
Phosphorus	milligrams per litre	Quarterly during discharge	Grab sample

M2.3 For the purposes of the table(s) above Special Method 1 means using volume results and monthly Phosphorus concentrations at point 2 to calculate the annual load of Phosphorus.

## M3 Testing methods - concentration limits

M3.1 Subject to any express provision to the contrary in this licence, monitoring for the concentration of a pollutant discharged to waters or applied to a utilisation area must be done in accordance with the Approved Methods Publication unless another method has been approved by the EPA in writing before any tests are conducted.

# Environment Protection Licence

Licence - 13042



## M4 Recording of pollution complaints

- M4.1 The licensee must keep a legible record of all complaints made to the licensee or any employee or agent of the licensee in relation to pollution arising from any activity to which this licence applies.
- M4.2 The record must include details of the following:
- a) the date and time of the complaint;
  - b) the method by which the complaint was made;
  - c) any personal details of the complainant which were provided by the complainant or, if no such details were provided, a note to that effect;
  - d) the nature of the complaint;
  - e) the action taken by the licensee in relation to the complaint, including any follow-up contact with the complainant; and
  - f) if no action was taken by the licensee, the reasons why no action was taken.
- M4.3 The record of a complaint must be kept for at least 4 years after the complaint was made.
- M4.4 The record must be produced to any authorised officer of the EPA who asks to see them.

## M5 Telephone complaints line

- M5.1 The licensee must operate during its operating hours a telephone complaints line for the purpose of receiving any complaints from members of the public in relation to activities conducted at the premises or by the vehicle or mobile plant, unless otherwise specified in the licence.
- M5.2 The licensee must notify the public of the complaints line telephone number and the fact that it is a complaints line so that the impacted community knows how to make a complaint.
- M5.3 The preceding two conditions do not apply until 3 months after:
- a) the date of the issue of this licence or
  - b) if this licence is a replacement licence within the meaning of the Protection of the Environment Operations (Savings and Transitional) Regulation 1998, the date on which a copy of the licence was served on the licensee under clause 10 of that regulation.
- M5.4 For the purpose of condition M5.1, operating hours are defined as twenty-four hours a day, seven days a week.
- M5.5 The public notification referred to in condition M5.2 must include specific reference to the fact that the complaints line may be used by the community for the reporting of overflows.

## M6 Requirement to monitor volume or mass

- M6.1 For each discharge point or utilisation area specified below, the licensee must monitor:
- a) the volume of liquids discharged to water or applied to the area;
  - b) the mass of solids applied to the area;
  - c) the mass of pollutants emitted to the air;

# Environment Protection Licence

Licence - 13042



at the frequency and using the method and units of measure, specified below.

## POINT 2

Frequency	Unit of Measure	Sampling Method
Daily	kilolitres per day	Magnetic flow meter

## POINT 3

Frequency	Unit of Measure	Sampling Method
Daily	kilolitres per day	Magnetic flow meter

M6.2 In the event that the licensee cannot comply with a volume monitoring method as required by this licence solely due to the failure or malfunction of essential monitoring equipment, volume may be estimated using another agreed method approved in writing by the EPA. This provision only applies for the duration of the failure or malfunction. The licensee is to rectify the failure or malfunction as soon as practicable.

M6.3 The licensee must:

- a) submit in writing to the EPA a proposal for a method of volume estimation; or
- b) use a method of volume estimation already approved in writing by the EPA,

to be used in the event that essential monitoring equipment referred to in the previous condition has failed or malfunctioned.

## M7 Requirement to record overflow or bypass incidents

M7.1 From July 2009 the licensee must record the following details in relation to each observed or reported overflow from the reticulation system and from the sewage treatment plant:

- a) the location of the overflow;
- b) the date, estimated start time and estimated duration of the overflow;
- c) the estimated volume of the overflow;
- d) a description of the receiving environment of the overflow;
- e) classification as a dry or wet weather overflow;
- f) the probable cause of the overflow;
- g) any actions taken to stop the overflow happening;
- h) any actions taken to clean up the overflow; and
- i) any actions taken to prevent the overflow happening again.

## M8 Other monitoring and recording conditions

M8.1 Biosolids at the premises must be recorded, monitored and classified in accordance with the Biosolids Guidelines, to the extent that those Guidelines are applicable, or as otherwise approved in writing by the EPA.

M8.2 The licensee must record the volumes of effluent that are disposed by effluent reuse. Each year

# Environment Protection Licence



Licence - 13042

the licensee must submit with the Annual Return information detailing;

- a) The amount of effluent irrigated at identification point 3;
- b) The amount of effluent discharged at identification point 1; and
- c) The percentage of effluent irrigated over the licensing year.

Note: The Environmental Impact Statement for the Stroud WWTP investigated the impacts of discharges. To protect downstream water quality the system has been designed to sustainably irrigate about 95% of effluent. The discharge limits shown in this licence are reflective of the majority of the effluent being sustainably reused.

## 6 Reporting Conditions

### R1 Annual return documents

R1.1 The licensee must complete and supply to the EPA an Annual Return in the approved form comprising:

- a) a Statement of Compliance; and
- b) a Monitoring and Complaints Summary.

At the end of each reporting period, the EPA will provide to the licensee a copy of the form that must be completed and returned to the EPA.

R1.2 An Annual Return must be prepared in respect of each reporting period, except as provided below.

Note: The term "reporting period" is defined in the dictionary at the end of this licence. Do not complete the Annual Return until after the end of the reporting period.

R1.3 Where this licence is transferred from the licensee to a new licensee:

- a) the transferring licensee must prepare an Annual Return for the period commencing on the first day of the reporting period and ending on the date the application for the transfer of the licence to the new licensee is granted; and
- b) the new licensee must prepare an Annual Return for the period commencing on the date the application for the transfer of the licence is granted and ending on the last day of the reporting period.

Note: An application to transfer a licence must be made in the approved form for this purpose.

R1.4 Where this licence is surrendered by the licensee or revoked by the EPA or Minister, the licensee must prepare an Annual Return in respect of the period commencing on the first day of the reporting period and ending on:

- a) in relation to the surrender of a licence - the date when notice in writing of approval of the surrender is given; or
- b) in relation to the revocation of the licence - the date from which notice revoking the licence operates.

R1.5 The Annual Return for the reporting period must be supplied to the EPA by registered post not later than 60 days after the end of each reporting period or in the case of a transferring licence not later than 60 days after the date the transfer was granted (the 'due date').

R1.6 The licensee must retain a copy of the Annual Return supplied to the EPA for a period of at least

# Environment Protection Licence

Licence - 13042



4 years after the Annual Return was due to be supplied to the EPA.

R1.7 Within the Annual Return, the Statement of Compliance must be certified and the Monitoring and Complaints Summary must be signed by:

- a) the licence holder; or
- b) by a person approved in writing by the EPA to sign on behalf of the licence holder.

R1.8 A person who has been given written approval to certify a certificate of compliance under a licence issued under the Pollution Control Act 1970 is taken to be approved for the purpose of this condition until the date of first review of this licence.

## R2 Notification of environmental harm

Note: The licensee or its employees must notify the EPA of incidents causing or threatening material harm to the environment as soon as practicable after the person becomes aware of the incident in accordance with the requirements of Part 5.7 of the Act.

R2.1 Notifications must be made by telephoning the Environment Line service on 131 555.

R2.2 The licensee must provide written details of the notification to the EPA within 7 days of the date on which the incident occurred.

## R3 Written report

R3.1 Where an authorised officer of the EPA suspects on reasonable grounds that:

- a) where this licence applies to premises, an event has occurred at the premises; or
- b) where this licence applies to vehicles or mobile plant, an event has occurred in connection with the carrying out of the activities authorised by this licence, and the event has caused, is causing or is likely to cause material harm to the environment (whether the harm occurs on or off premises to which the licence applies), the authorised officer may request a written report of the event.

R3.2 The licensee must make all reasonable inquiries in relation to the event and supply the report to the EPA within such time as may be specified in the request.

R3.3 The request may require a report which includes any or all of the following information:

- a) the cause, time and duration of the event;
- b) the type, volume and concentration of every pollutant discharged as a result of the event;
- c) the name, address and business hours telephone number of employees or agents of the licensee, or a specified class of them, who witnessed the event;
- d) the name, address and business hours telephone number of every other person (of whom the licensee is aware) who witnessed the event, unless the licensee has been unable to obtain that information after making reasonable effort;
- e) action taken by the licensee in relation to the event, including any follow-up contact with any complainants;
- f) details of any measure taken or proposed to be taken to prevent or mitigate against a recurrence of such an event; and
- g) any other relevant matters.



# Environment Protection Licence



Licence - 13042

R3.4 The EPA may make a written request for further details in relation to any of the above matters if it is not satisfied with the report provided by the licensee. The licensee must provide such further details to the EPA within the time specified in the request.

## **R4 Notification of bypass or overflow incidents**

R4.1 Where either:

- a) sewage or partially treated sewage is discharged from the premises as a result of a bypass of the sewage treatment plant, or
- b) an observed or reported overflow has occurred from the reticulation system, and overflow or bypass may pose a risk to public health, the licensee is to promptly give appropriate notification to any parties that are likely to be affected, including:
  - i) the potentially affected community,
  - ii) the Safe Food NSW Shellfish Quality Assurance Program, where the bypass or overflow could have potential impacts on shellfish production; and
  - iii) the Department of Health.

R4.2 When the licensee notifies the Department of Health, or Safe Food NSW Shellfish Quality Assurance Program, of a bypass or overflow incident, the licensee must also notify the EPA by telephoning its Pollution Line service on 131 555. Notifications are to be given as soon as practicable after the licensee, or one of the licensee's employees or agents becomes aware of the incident, and must include all relevant information required by this licence.

## **R5 Annual system performance report**

R5.1 The licensee must supply to the EPA an Annual System Performance Report not later than 60 days after the end of each reporting period.

R5.2 The report is to supplement the Annual Return and must include but need not be limited to:

- a) the 50 percentile, 90 percentile, 100 percentile and 3DGM values calculated from the monitoring data required by this licence for the reporting period for each pollutant which has corresponding concentration limits specified in this licence;
- b) the total amounts of biosolids, as classified in the Biosolids Guideline, disposed of on-site, off-site and to landfill during the reporting period;
- c) a diagram showing the major process elements, discharge points and monitoring points at the premises' sewage treatment plant(s), where there has been any significant change since the previous reporting period or this information has not been provided previously to the EPA;
- d) the number of dry and wet weather bypasses recorded over the reporting period (recorded in accordance with condition M7);
- e) a breakdown of the total number of complaints received by the licensee during the reporting period in relation to the premises into categories of "odours – sewage treatment plant", "odours – reticulation system", "water pollution – sewage treatment plant", "water pollution – reticulation system" and any other category indicated by the complaints;
- f) a summary of observed, reported or recorded wet weather overflows and observed, reported or recorded dry weather overflows and sewage treatment plant bypasses. These data are to be for the current reporting period and for the four previous twelve-month periods, for which data has been collected. Any significant actions taken to address bypasses or overflows are to be noted;

# Environment Protection Licence

Licence - 13042



- g) the amount of rainfall measured at a rain gauge at the STP, or at the rain gauge closest to the centre of the catchment of the sewage treatment system, for each month of the reporting period; and
- h) a brief progress report on the implementation over the reporting period of actions specified in PRP100.

R5.3 The Annual System Performance Report must be presented in a format approved in writing by the EPA.

## 7 General Conditions

### G1 Copy of licence kept at the premises or plant

- G1.1 A copy of this licence must be kept at the premises to which the licence applies.
- G1.2 The licence must be produced to any authorised officer of the EPA who asks to see it.
- G1.3 The licence must be available for inspection by any employee or agent of the licensee working at the premises.

Note: For the purposes of this condition, “the premises” refers to each Sewage Treatment Plant(s) described in condition A2.1.

### G2 Contact number for incidents and responsible employees

- G2.1 The licensee must operate 24-hour telephone contact lines for the purpose of enabling the EPA to directly contact one or more representatives of the licensee who can:
  - a) respond at all times to incidents relating to the premises; and
  - b) contact the licensee’s senior employees or agents authorised at all times to:
    - i) speak on behalf of the licensee; and
    - ii) provide any information or document required under this licence.
- G2.2 The licensee is to inform the EPA in writing of the representative or representatives and their telephone number(s) by The EPA must be notified of the telephone number(s) on commencement of its/their operation.
- G2.3 The licensee is to inform the EPA in writing of the appointment of any subsequent contact persons, or changes to the person’s contact details as soon as practicable and in any event within fourteen days of the appointment or change.

### G3 Signage

- G3.1 The location of EPA point number(s) 1 and 2 must be clearly marked by signs that indicate the point identification number used in this licence and be located as close as practical to the point.

# Environment Protection Licence

Licence - 13042



## Dictionary

### General Dictionary

<b>3DGM [in relation to a concentration limit]</b>	Means the three day geometric mean, which is calculated by multiplying the results of the analysis of three samples collected on consecutive days and then taking the cubed root of that amount. Where one or more of the samples is zero or below the detection limit for the analysis, then 1 or the detection limit respectively should be used in place of those samples
<b>Act</b>	Means the Protection of the Environment Operations Act 1997
<b>activity</b>	Means a scheduled or non-scheduled activity within the meaning of the Protection of the Environment Operations Act 1997
<b>actual load</b>	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
<b>AM</b>	Together with a number, means an ambient air monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
<b>AMG</b>	Australian Map Grid
<b>anniversary date</b>	The anniversary date is the anniversary each year of the date of issue of the licence. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
<b>annual return</b>	Is defined in R1.1
<b>Approved Methods Publication</b>	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
<b>assessable pollutants</b>	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
<b>BOD</b>	Means biochemical oxygen demand
<b>CEM</b>	Together with a number, means a continuous emission monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
<b>COD</b>	Means chemical oxygen demand
<b>composite sample</b>	Unless otherwise specifically approved in writing by the EPA, a sample consisting of 24 individual samples collected at hourly intervals and each having an equivalent volume.
<b>cond.</b>	Means conductivity
<b>environment</b>	Has the same meaning as in the Protection of the Environment Operations Act 1997
<b>environment protection legislation</b>	Has the same meaning as in the Protection of the Environment Administration Act 1991
<b>EPA</b>	Means Environment Protection Authority of New South Wales.
<b>fee-based activity classification</b>	Means the numbered short descriptions in Schedule 1 of the Protection of the Environment Operations (General) Regulation 2009.
<b>general solid waste (non-putrescible)</b>	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997

# Environment Protection Licence



Licence - 13042

<b>flow weighted composite sample</b>	Means a sample whose composites are sized in proportion to the flow at each composites time of collection.
<b>general solid waste (putrescible)</b>	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
<b>grab sample</b>	Means a single sample taken at a point at a single time
<b>hazardous waste</b>	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
<b>licensee</b>	Means the licence holder described at the front of this licence
<b>load calculation protocol</b>	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
<b>local authority</b>	Has the same meaning as in the Protection of the Environment Operations Act 1997
<b>material harm</b>	Has the same meaning as in section 147 Protection of the Environment Operations Act 1997
<b>MBAS</b>	Means methylene blue active substances
<b>Minister</b>	Means the Minister administering the Protection of the Environment Operations Act 1997
<b>mobile plant</b>	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
<b>motor vehicle</b>	Has the same meaning as in the Protection of the Environment Operations Act 1997
<b>O&amp;G</b>	Means oil and grease
<b>percentile [in relation to a concentration limit of a sample]</b>	Means that percentage [eg.50%] of the number of samples taken that must meet the concentration limit specified in the licence for that pollutant over a specified period of time. In this licence, the specified period of time is the Reporting Period unless otherwise stated in this licence.
<b>plant</b>	Includes all plant within the meaning of the Protection of the Environment Operations Act 1997 as well as motor vehicles.
<b>pollution of waters [or water pollution]</b>	Has the same meaning as in the Protection of the Environment Operations Act 1997
<b>premises</b>	Means the premises described in condition A2.1
<b>public authority</b>	Has the same meaning as in the Protection of the Environment Operations Act 1997
<b>regional office</b>	Means the relevant EPA office referred to in the Contacting the EPA document accompanying this licence
<b>reporting period</b>	For the purposes of this licence, the reporting period means the period of 12 months after the issue of the licence, and each subsequent period of 12 months. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
<b>restricted solid waste</b>	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
<b>scheduled activity</b>	Means an activity listed in Schedule 1 of the Protection of the Environment Operations Act 1997
<b>special waste</b>	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
<b>TM</b>	Together with a number, means a test method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .

# Environment Protection Licence



Licence - 13042

<b>TSP</b>	Means total suspended particles
<b>TSS</b>	Means total suspended solids
<b>Type 1 substance</b>	Means the elements antimony, arsenic, cadmium, lead or mercury or any compound containing one or more of those elements
<b>Type 2 substance</b>	Means the elements beryllium, chromium, cobalt, manganese, nickel, selenium, tin or vanadium or any compound containing one or more of those elements
<b>utilisation area</b>	Means any area shown as a utilisation area on a map submitted with the application for this licence
<b>waste</b>	Has the same meaning as in the Protection of the Environment Operations Act 1997
<b>waste type</b>	Means liquid, restricted solid waste, general solid waste (putrescible), general solid waste (non-putrescible), special waste or hazardous waste

Mr Peter Jamieson

Environment Protection Authority

(By Delegation)

Date of this edition: 14-May-2009

## End Notes

2 Licence varied by notice 1501120 issued on 16-Sep-2011