

Environment Protection Licence

Licence - 13036



Licence Details	
Number:	13036
Anniversary Date:	01-July

Licensee
SNOWY HYDRO LIMITED
PO BOX 332 MONARO HWY
COOMA NSW 2630

Premises
COLONGRA POWER STATION
OFF SCENIC DRIVE
BUDGEWOI NSW 2262

Scheduled Activity
Electricity Generation

Fee Based Activity	Scale
Generation of electrical power from gas	> 1000-4000 Gwh generated

Region
North - Hunter
Ground Floor, NSW Govt Offices, 117 Bull Street
NEWCASTLE WEST NSW 2302
Phone: (02) 4908 6800
Fax: (02) 4908 6810
PO Box 488G NEWCASTLE
NSW 2300

Environment Protection Licence

Licence - 13036



INFORMATION ABOUT THIS LICENCE	4
Dictionary	4
Responsibilities of licensee	4
Variation of licence conditions	4
Duration of licence	4
Licence review	4
Fees and annual return to be sent to the EPA	4
Transfer of licence	5
Public register and access to monitoring data	5
1 ADMINISTRATIVE CONDITIONS	6
A1 What the licence authorises and regulates	6
A2 Premises or plant to which this licence applies	6
A3 Information supplied to the EPA	6
2 DISCHARGES TO AIR AND WATER AND APPLICATIONS TO LAND	7
P1 Location of monitoring/discharge points and areas	7
3 LIMIT CONDITIONS	7
L1 Pollution of waters	7
L2 Load limits	7
L3 Concentration limits	8
L4 Waste	8
L5 Noise limits	8
4 OPERATING CONDITIONS	9
O1 Activities must be carried out in a competent manner	9
O2 Maintenance of plant and equipment	10
O3 Emergency response	10
O4 Other operating conditions	10
5 MONITORING AND RECORDING CONDITIONS	11
M1 Monitoring records	11
M2 Requirement to monitor concentration of pollutants discharged	11
M3 Testing methods - concentration limits	12
M4 Testing methods - load limits	12
M5 Recording of pollution complaints	13
M6 Telephone complaints line	13
6 REPORTING CONDITIONS	13

Environment Protection Licence



Licence - 13036	
R1 Annual return documents	13
R2 Notification of environmental harm	14
R3 Written report	15
7 GENERAL CONDITIONS	15
G1 Copy of licence kept at the premises or plant	15
DICTIONARY	16
General Dictionary	16

Environment Protection Licence

Licence - 13036



Information about this licence

Dictionary

A definition of terms used in the licence can be found in the dictionary at the end of this licence.

Responsibilities of licensee

Separate to the requirements of this licence, general obligations of licensees are set out in the Protection of the Environment Operations Act 1997 ("the Act") and the Regulations made under the Act. These include obligations to:

- ensure persons associated with you comply with this licence, as set out in section 64 of the Act;
- control the pollution of waters and the pollution of air (see for example sections 120 - 132 of the Act);
- report incidents causing or threatening material environmental harm to the environment, as set out in Part 5.7 of the Act.

Variation of licence conditions

The licence holder can apply to vary the conditions of this licence. An application form for this purpose is available from the EPA.

The EPA may also vary the conditions of the licence at any time by written notice without an application being made.

Where a licence has been granted in relation to development which was assessed under the Environmental Planning and Assessment Act 1979 in accordance with the procedures applying to integrated development, the EPA may not impose conditions which are inconsistent with the development consent conditions until the licence is first reviewed under Part 3.6 of the Act.

Duration of licence

This licence will remain in force until the licence is surrendered by the licence holder or until it is suspended or revoked by the EPA or the Minister. A licence may only be surrendered with the written approval of the EPA.

Licence review

The Act requires that the EPA review your licence at least every 5 years after the issue of the licence, as set out in Part 3.6 and Schedule 5 of the Act. You will receive advance notice of the licence review.

Fees and annual return to be sent to the EPA

For each licence fee period you must pay:

- an administrative fee; and
- a load-based fee (if applicable).

Environment Protection Licence

Licence - 13036



The EPA publication “A Guide to Licensing” contains information about how to calculate your licence fees. The licence requires that an Annual Return, comprising a Statement of Compliance and a summary of any monitoring required by the licence (including the recording of complaints), be submitted to the EPA. The Annual Return must be submitted within 60 days after the end of each reporting period. See condition R1 regarding the Annual Return reporting requirements.

Usually the licence fee period is the same as the reporting period.

Transfer of licence

The licence holder can apply to transfer the licence to another person. An application form for this purpose is available from the EPA.

Public register and access to monitoring data

Part 9.5 of the Act requires the EPA to keep a public register of details and decisions of the EPA in relation to, for example:

- licence applications;
- licence conditions and variations;
- statements of compliance;
- load based licensing information; and
- load reduction agreements.

Under s320 of the Act application can be made to the EPA for access to monitoring data which has been submitted to the EPA by licensees.

This licence is issued to:

SNOWY HYDRO LIMITED
PO BOX 332 MONARO HWY
COOMA NSW 2630

subject to the conditions which follow.

Environment Protection Licence

Licence - 13036



1 Administrative Conditions

A1 What the licence authorises and regulates

A1.1 This licence authorises the carrying out of the scheduled activities listed below at the premises specified in A2. The activities are listed according to their scheduled activity classification, fee-based activity classification and the scale of the operation.

Unless otherwise further restricted by a condition of this licence, the scale at which the activity is carried out must not exceed the maximum scale specified in this condition.

Scheduled Activity	Fee Based Activity	Scale
Electricity Generation	Generation of electrical power from gas	> 1000 - 4000 Gwh generated

A2 Premises or plant to which this licence applies

A2.1 The licence applies to the following premises:

Premises Details
COLONGRA POWER STATION
OFF SCENIC DRIVE
BUDGEWOI
NSW 2262
AREA SHADED GREEN AND IDENTIFIED AS COLONGRA LAND IN DRAWING NO 130285W_04 TITLED, 'PROPOSED PLAN OF PROPOSED ACQUISITION OF LAND BEING LOT 5 DP 1201414 MUNMORAH POWER STATION, COLONGRA,' DATED 2 DECEMBER 2014 WHICH INCLUDES LOT 22 DP 1134580 (EPA REFERENCE DOC15/12747).

A3 Information supplied to the EPA

A3.1 Works and activities must be carried out in accordance with the proposal contained in the licence application, except as expressly provided by a condition of this licence.

In this condition the reference to "the licence application" includes a reference to:

- the applications for any licences (including former pollution control approvals) which this licence replaces under the Protection of the Environment Operations (Savings and Transitional) Regulation 1998; and
- the licence information form provided by the licensee to the EPA to assist the EPA in connection with the issuing of this licence.

Environment Protection Licence

Licence - 13036



2 Discharges to Air and Water and Applications to Land

P1 Location of monitoring/discharge points and areas

P1.1 The following points referred to in the table below are identified in this licence for the purposes of monitoring and/or the setting of limits for the emission of pollutants to the air from the point.

Air

EPA identification no.	Type of Monitoring Point	Type of Discharge Point	Location Description
1	Discharge to air - GT Stack 1	Discharge to air - GT Stack 1	Stack from gas turbine 1 Stack Height 35 Metres
2	Discharge to air - GT Stack 2	Discharge to air - GT Stack 2	Stack from gas turbine 2 Stack Height 35 Metres
3	Discharge to air - GT Stack 3	Discharge to air - GT Stack 3	Stack from Gas Turbine 3, Stack Height 35 Metres
4	Discharge to air - GT Stack 4	Discharge to air - GT Stack 4	Stack from gas turbine 4 , stack height 35 metres

P1.2 The following utilisation areas referred to in the table below are identified in this licence for the purposes of the monitoring and/or the setting of limits for any application of solids or liquids to the utilisation area.

3 Limit Conditions

L1 Pollution of waters

L1.1 Except as may be expressly provided in any other condition of this licence, the licensee must comply with section 120 of the Protection of the Environment Operations Act 1997.

L2 Load limits

L2.1 The actual load of an assessable pollutant discharged from the premises during the reporting period must not exceed the load limit specified for the assessable pollutant in the table below.

L2.2 The actual load of an assessable pollutant must be calculated in accordance with the relevant load calculation protocol.

Assessable Pollutant	Load limit (kg)
Nitrogen Oxides (Air)	

Note: An assessable pollutant is a pollutant which affects the licence fee payable for the licence.

Environment Protection Licence

Licence - 13036



L3 Concentration limits

- L3.1 For each monitoring/discharge point or utilisation area specified in the table below (by a point number), the concentration of a pollutant discharged at that point, or applied to that area, must not exceed the concentration limits specified for that pollutant in the table.
- L3.2 To avoid any doubt, this condition does not authorise the pollution of waters by any pollutant other than those specified in the table.
- L3.3 Air Concentration Limits

POINT 1,2,3,4

Pollutant	Units of measure	100 percentile concentration limit	Reference conditions	Oxygen correction	Averaging period
Nitrogen Oxides	milligrams per cubic metre	60	Dry, 273K, 101.3kPa	15% O ₂	1 hour

Note: Nitrogen oxides means: Nitrogen dioxide (NO₂) or Nitric oxide (NO) or both, as NO₂ equivalent.

- L3.4 While operating on distillate fuels only the concentration limit for oxides of nitrogen for all discharge points from gas turbines listed in this licence shall be increased from 60 milligrams per cubic metre to 90 milligrams per cubic metre.

Note: This condition does not authorise the type of fuel used and does not effect any condition of this licence relating to fuels used in firing fuel burning equipment regulated by this license.

- L3.5 The limits contained in the licence do not apply during a period of start up or shut down.

Start up and shut down have the same meaning for the purposes of this licence as defined in the Protection Of The Environment Operations (Clean Air) Regulation 2010.

Note: While the limits contained in this licence do not apply under the specified periods, the occupier of the premises concerned will be still subject to the requirements of section 128(2) of the Protection of The Environment Operations Act 1997.

L4 Waste

- L4.1 The licensee must not cause, permit or allow any waste generated outside the premises to be received at the premises for storage, treatment, processing, reprocessing or disposal or any waste generated at the premises to be disposed of at the premises, except as expressly permitted by the licence.

L5 Noise limits

- L5.1 Operational Noise

The Licensee shall operate and maintain the premises and plant to ensure that the noise contributions

Environment Protection Licence

Licence - 13036



from the project to the background acoustic environment does not exceed the maximum allowable noise contributions specified in the table below, at those locations and during the periods indicated in that table.

The maximum allowable noise contributions apply under wind speeds up to 3 ms^{-1} (measured at 10 metres above ground level), or under temperature inversion conditions of up to $3^\circ\text{C}/100$ metres.

Location	Day	Evening	Night
	(7am to 6pm Mon to Sat and 8am to 6pm Sun and P/Hol)	(6pm to 10pm any day)	(10pm to 7am Mon to Sat and 10pm to 8am Sun and P/Hol)
	L _{Aeq} (15 Minutes)	L _{Aeq} (15 Minutes)	L _{Aeq} (15 Minutes)
Sunnylake Caravan Park	40	40	40
Macleay Avenue	45	45	45
Woolana Avenue, Halekulani	41	41	41
Ulana Avenue, Budgewoi	41	41	41
Barega Close, Buff Point	39.5	39.5	39.5
Barker Avenue, San Remo	40	40	40
Denman Street, Colongra	39.5	39.5	39.5

Note: For the purposes of assessment of noise contributions specified under this licence, noise from the premises shall be measured as follows;

- a) At any point within the residential boundary, or at any point within 30 metres of the dwelling where the dwelling is more than 30 metres from the boundary; and
- b) Subject to modification factors provided in section 4 of the *New South Wales Industrial Noise Policy* (EPA2000), where applicable.

Should direct measurement of noise from the premises be impractical the licensee may apply to the EPA to use an alternative noise assessment method (refer to section 11 of the *New South Wales Industrial Noise Policy* (EPA2000))

EPA approval of alternative noise assessment methods must be obtained prior to the implementation of the assessment method.

4 Operating Conditions

O1 Activities must be carried out in a competent manner

O1.1 Licensed activities must be carried out in a competent manner.

This includes:

- a) the processing, handling, movement and storage of materials and substances used to carry out the activity; and
- b) the treatment, storage, processing, reprocessing, transport and disposal of waste generated by the activity.

Environment Protection Licence

Licence - 13036



O2 Maintenance of plant and equipment

- O2.1 All plant and equipment installed at the premises or used in connection with the licensed activity:
- must be maintained in a proper and efficient condition; and
 - must be operated in a proper and efficient manner.

O3 Emergency response

- O3.1 The licensee must maintain, and implement as necessary, a current Pollution Incident Response Management Plan (PIRMP) for the premises. The PIRMP must be developed in accordance with the requirements in Part 5.7A of the *Protection of the Environment Operations (POEO) Act 1997* and POEO regulations. The licensee must keep the incident response plan on the premises at all times. The incident response plan must document systems and procedures to deal with all types of incidents (e.g. spills, explosions or fire) that may occur at the premises or that may be associated with activities that occur at the premises and which are likely to cause harm to the environment. The PIRMP must be tested at least annually or following a pollution incident.

O4 Other operating conditions

- O4.1 Fuels that may be used to fire the turbines are listed in the project approval issued by the Department of Planning.

Note: The project approval issued differs from EPA recommendations on fuel usage, accordingly EPA is unable to include conditions within this licence regarding fuel usage, the licensee should consult the project approval for information regarding restrictions on fuel usage by the turbines.

To avoid any doubt nothing in this condition allows or permits the limits contained within this licence to be exceeded.

- O4.2 The emergency diesel generators powered by internal combustion compression ignition engines must only be used for emergency black start as specified in the environmental assessment.

Operation of the emergency diesel generators is permitted for testing and maintenance of the units.

- O4.3 The licensee must store and handle all liquid chemicals on the site within bunded areas.

Bunded areas must be constructed and maintained to the following;

- To any relevant Australian Standards for the liquids being stored
- Within a bunded area with a minimum bund capacity of 110% of the volume of the largest single stored volume within the bund; and
- The EPA's Environment Protection Manual Technical Bulletin "Bunding and Spill Management"

For the purposes of the licence any tanks or other storage containers that are interconnected and may feed either by gravity or automated pumps must be considered as a single stored volume for the purposes

Environment Protection Licence

Licence - 13036



of this condition.

O4.4 Weather Station

The licensee must install, operate and maintain, a weather recording station capable of measuring and recording rainfall, wind speed, wind direction, temperature and inversion conditions.

All installation and measurements must be in accordance with the relevant standards or specifications for weather monitoring equipment.

The monitored information must be stored for a period of 3 years from the date of collection and produced to an authorised officer of the EPA upon request.

The Weather Station must record the information set out in the table below when the power station is generating electricity.

Recorded Parameter	Frequency of Recordings
Rainfall	Hourly
Wind Speed and Direction	5 Minute Average
Temperature at Ground Level	5 Minute Average
Temperature at 10 Metres above the ground	5 Minute Average

5 Monitoring and Recording Conditions

M1 Monitoring records

M1.1 The results of any monitoring required to be conducted by this licence or a load calculation protocol must be recorded and retained as set out in this condition.

M1.2 All records required to be kept by this licence must be:

- in a legible form, or in a form that can readily be reduced to a legible form;
- kept for at least 4 years after the monitoring or event to which they relate took place; and
- produced in a legible form to any authorised officer of the EPA who asks to see them.

M1.3 The following records must be kept in respect of any samples required to be collected for the purposes of this licence:

- the date(s) on which the sample was taken;
- the time(s) at which the sample was collected;
- the point at which the sample was taken; and
- the name of the person who collected the sample.

M2 Requirement to monitor concentration of pollutants discharged

M2.1 For each monitoring/discharge point or utilisation area specified below (by a point number), the licensee must monitor (by sampling and obtaining results by analysis) the concentration of each pollutant specified

Environment Protection Licence

Licence - 13036



in Column 1. The licensee must use the sampling method, units of measure, and sample at the frequency, specified opposite in the other columns:

M2.2 Air Monitoring Requirements

POINT 1,2,3,4

Pollutant	Units of measure	Frequency	Sampling Method
Carbon dioxide	percent	Yearly	TM-24
Dry gas density	kilograms per cubic metre	Yearly	TM-23
Moisture content	percent	Yearly	TM-22
Molecular weight of stack gases	grams per gram mole	Yearly	TM-23
Nitrogen Oxides	milligrams per cubic metre	Continuous	CEM-2
Oxygen (O ₂)	percent	Yearly	TM-25
Temperature	Celsius	Yearly	TM-2
Velocity	metres per second	Yearly	TM-2
Volumetric flowrate	cubic metres per second	Yearly	TM-2

Note: Nitrogen oxides means: Nitrogen dioxide (NO₂) or Nitric oxide (NO) or both, as NO₂ equivalent.

M3 Testing methods - concentration limits

M3.1 Monitoring for the concentration of a pollutant emitted to the air required to be conducted by this licence must be done in accordance with:

- any methodology which is required by or under the Act to be used for the testing of the concentration of the pollutant; or
- if no such requirement is imposed by or under the Act, any methodology which a condition of this licence requires to be used for that testing; or
- if no such requirement is imposed by or under the Act or by a condition of this licence, any methodology approved in writing by the EPA for the purposes of that testing prior to the testing taking place.

Note: The *Protection of the Environment Operations (Clean Air) Regulation 2010* requires testing for certain purposes to be conducted in accordance with test methods contained in the publication "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW".

M4 Testing methods - load limits

Note: Division 3 of the *Protection of the Environment Operations (General) Regulation 2009* requires that monitoring of actual loads of assessable pollutants listed in L2.2 must be carried out in accordance with the relevant load calculation protocol set out for the fee-based activity classification listed in the

Environment Protection Licence

Licence - 13036



Administrative Conditions of this licence.

M5 Recording of pollution complaints

- M5.1 The licensee must keep a legible record of all complaints made to the licensee or any employee or agent of the licensee in relation to pollution arising from any activity to which this licence applies.
- M5.2 The record must include details of the following:
- a) the date and time of the complaint;
 - b) the method by which the complaint was made;
 - c) any personal details of the complainant which were provided by the complainant or, if no such details were provided, a note to that effect;
 - d) the nature of the complaint;
 - e) the action taken by the licensee in relation to the complaint, including any follow-up contact with the complainant; and
 - f) if no action was taken by the licensee, the reasons why no action was taken.
- M5.3 The record of a complaint must be kept for at least 4 years after the complaint was made.
- M5.4 The record must be produced to any authorised officer of the EPA who asks to see them.

M6 Telephone complaints line

- M6.1 The licensee must operate during its operating hours a telephone complaints line for the purpose of receiving any complaints from members of the public in relation to activities conducted at the premises or by the vehicle or mobile plant, unless otherwise specified in the licence.
- M6.2 The licensee must notify the public of the complaints line telephone number and the fact that it is a complaints line so that the impacted community knows how to make a complaint.
- M6.3 The preceding two conditions do not apply until 3 months after: the date of the issue of this licence.

6 Reporting Conditions

R1 Annual return documents

- R1.1 The licensee must complete and supply to the EPA an Annual Return in the approved form comprising:
- a) a Statement of Compliance; and
 - b) a Monitoring and Complaints Summary.
- At the end of each reporting period, the EPA will provide to the licensee a copy of the form that must be completed and returned to the EPA.
- R1.2 An Annual Return must be prepared in respect of each reporting period, except as provided below.
- R1.3 Where this licence is transferred from the licensee to a new licensee:

Environment Protection Licence



Licence - 13036

- a) the transferring licensee must prepare an Annual Return for the period commencing on the first day of the reporting period and ending on the date the application for the transfer of the licence to the new licensee is granted; and
- b) the new licensee must prepare an Annual Return for the period commencing on the date the application for the transfer of the licence is granted and ending on the last day of the reporting period.

R1.4 Where this licence is surrendered by the licensee or revoked by the EPA or Minister, the licensee must prepare an Annual Return in respect of the period commencing on the first day of the reporting period and ending on:

- a) in relation to the surrender of a licence - the date when notice in writing of approval of the surrender is given; or
- b) in relation to the revocation of the licence - the date from which notice revoking the licence operates.

R1.5 The Annual Return for the reporting period must be supplied to the EPA by registered post not later than 60 days after the end of each reporting period or in the case of a transferring licence not later than 60 days after the date the transfer was granted (the 'due date').

R1.6 Where the licensee is unable to complete a part of the Annual Return by the due date because the licensee was unable to calculate the actual load of a pollutant due to circumstances beyond the licensee's control, the licensee must notify the EPA in writing as soon as practicable, and in any event not later than the due date. The notification must specify:

- a) the assessable pollutants for which the actual load could not be calculated; and
- b) the relevant circumstances that were beyond the control of the licensee.

R1.7 The licensee must retain a copy of the Annual Return supplied to the EPA for a period of at least 4 years after the Annual Return was due to be supplied to the EPA.

R1.8 Within the Annual Return, the Statement of Compliance must be certified and the Monitoring and Complaints Summary must be signed by:

- a) the licence holder; or
- b) by a person approved in writing by the EPA to sign on behalf of the licence holder.

Note: The term "reporting period" is defined in the dictionary at the end of this licence. Do not complete the Annual Return until after the end of the reporting period.

Note: An application to transfer a licence must be made in the approved form for this purpose.

R2 Notification of environmental harm

R2.1 Notifications must be made by telephoning the Environment Line service on 131 555.

R2.2 The licensee must provide written details of the notification to the EPA within 7 days of the date on which the incident occurred.

Note: The licensee or its employees must notify all relevant authorities of incidents causing or threatening material harm to the environment immediately after the person becomes aware of the incident in accordance with the requirements of Part 5.7 of the Act.

Environment Protection Licence

Licence - 13036



R3 Written report

- R3.1 Where an authorised officer of the EPA suspects on reasonable grounds that:
- a) where this licence applies to premises, an event has occurred at the premises; or
 - b) where this licence applies to vehicles or mobile plant, an event has occurred in connection with the carrying out of the activities authorised by this licence,
- and the event has caused, is causing or is likely to cause material harm to the environment (whether the harm occurs on or off premises to which the licence applies), the authorised officer may request a written report of the event.
- R3.2 The licensee must make all reasonable inquiries in relation to the event and supply the report to the EPA within such time as may be specified in the request.
- R3.3 The request may require a report which includes any or all of the following information:
- a) the cause, time and duration of the event;
 - b) the type, volume and concentration of every pollutant discharged as a result of the event;
 - c) the name, address and business hours telephone number of employees or agents of the licensee, or a specified class of them, who witnessed the event;
 - d) the name, address and business hours telephone number of every other person (of whom the licensee is aware) who witnessed the event, unless the licensee has been unable to obtain that information after making reasonable effort;
 - e) action taken by the licensee in relation to the event, including any follow-up contact with any complainants;
 - f) details of any measure taken or proposed to be taken to prevent or mitigate against a recurrence of such an event; and
 - g) any other relevant matters.
- R3.4 The EPA may make a written request for further details in relation to any of the above matters if it is not satisfied with the report provided by the licensee. The licensee must provide such further details to the EPA within the time specified in the request.

7 General Conditions

G1 Copy of licence kept at the premises or plant

- G1.1 A copy of this licence must be kept at the premises to which the licence applies.
- G1.2 The licence must be produced to any authorised officer of the EPA who asks to see it.
- G1.3 The licence must be available for inspection by any employee or agent of the licensee working at the premises.

Environment Protection Licence



Licence - 13036

Dictionary

General Dictionary

3DGM [in relation to a concentration limit]	Means the three day geometric mean, which is calculated by multiplying the results of the analysis of three samples collected on consecutive days and then taking the cubed root of that amount. Where one or more of the samples is zero or below the detection limit for the analysis, then 1 or the detection limit respectively should be used in place of those samples
Act	Means the Protection of the Environment Operations Act 1997
activity	Means a scheduled or non-scheduled activity within the meaning of the Protection of the Environment Operations Act 1997
actual load	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
AM	Together with a number, means an ambient air monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
AMG	Australian Map Grid
anniversary date	The anniversary date is the anniversary each year of the date of issue of the licence. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
annual return	Is defined in R1.1
Approved Methods Publication	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
assessable pollutants	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
BOD	Means biochemical oxygen demand
CEM	Together with a number, means a continuous emission monitoring method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .
COD	Means chemical oxygen demand
composite sample	Unless otherwise specifically approved in writing by the EPA, a sample consisting of 24 individual samples collected at hourly intervals and each having an equivalent volume.
cond.	Means conductivity
environment	Has the same meaning as in the Protection of the Environment Operations Act 1997
environment protection legislation	Has the same meaning as in the Protection of the Environment Administration Act 1991
EPA	Means Environment Protection Authority of New South Wales.
fee-based activity classification	Means the numbered short descriptions in Schedule 1 of the Protection of the Environment Operations (General) Regulation 2009.
general solid waste (non-putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997

Environment Protection Licence



Licence - 13036

flow weighted composite sample	Means a sample whose composites are sized in proportion to the flow at each composites time of collection.
general solid waste (putrescible)	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
grab sample	Means a single sample taken at a point at a single time
hazardous waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
licensee	Means the licence holder described at the front of this licence
load calculation protocol	Has the same meaning as in the Protection of the Environment Operations (General) Regulation 2009
local authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
material harm	Has the same meaning as in section 147 Protection of the Environment Operations Act 1997
MBAS	Means methylene blue active substances
Minister	Means the Minister administering the Protection of the Environment Operations Act 1997
mobile plant	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
motor vehicle	Has the same meaning as in the Protection of the Environment Operations Act 1997
O&G	Means oil and grease
percentile [in relation to a concentration limit of a sample]	Means that percentage [eg.50%] of the number of samples taken that must meet the concentration limit specified in the licence for that pollutant over a specified period of time. In this licence, the specified period of time is the Reporting Period unless otherwise stated in this licence.
plant	Includes all plant within the meaning of the Protection of the Environment Operations Act 1997 as well as motor vehicles.
pollution of waters [or water pollution]	Has the same meaning as in the Protection of the Environment Operations Act 1997
premises	Means the premises described in condition A2.1
public authority	Has the same meaning as in the Protection of the Environment Operations Act 1997
regional office	Means the relevant EPA office referred to in the Contacting the EPA document accompanying this licence
reporting period	For the purposes of this licence, the reporting period means the period of 12 months after the issue of the licence, and each subsequent period of 12 months. In the case of a licence continued in force by the Protection of the Environment Operations Act 1997, the date of issue of the licence is the first anniversary of the date of issue or last renewal of the licence following the commencement of the Act.
restricted solid waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
scheduled activity	Means an activity listed in Schedule 1 of the Protection of the Environment Operations Act 1997
special waste	Has the same meaning as in Part 3 of Schedule 1 of the Protection of the Environment Operations Act 1997
TM	Together with a number, means a test method of that number prescribed by the <i>Approved Methods for the Sampling and Analysis of Air Pollutants in New South Wales</i> .

Environment Protection Licence



Licence - 13036

TSP	Means total suspended particles
TSS	Means total suspended solids
Type 1 substance	Means the elements antimony, arsenic, cadmium, lead or mercury or any compound containing one or more of those elements
Type 2 substance	Means the elements beryllium, chromium, cobalt, manganese, nickel, selenium, tin or vanadium or any compound containing one or more of those elements
utilisation area	Means any area shown as a utilisation area on a map submitted with the application for this licence
waste	Has the same meaning as in the Protection of the Environment Operations Act 1997
waste type	Means liquid, restricted solid waste, general solid waste (putrescible), general solid waste (non - putrescible), special waste or hazardous waste

Mr Mark Hartwell

Environment Protection Authority

(By Delegation)

Date of this edition: 22-April-2009

End Notes

- 2 Licence varied by notice 1510420 issued on 05-Jun-2013
- 3 Licence varied by notice 1524039 issued on 09-Dec-2014
- 4 Licence varied by notice 1527970 issued on 27-Jan-2015
- 5 Licence transferred through application 1528154 approved on 30-Jan-2015 , which came into effect on 30-Jan-2015
- 6 Licence fee period changed by notice 1528601 on 22-Apr-2015
- 7 Licence varied by notice 1532343 issued on 27-Aug-2015